



# IEA EBC Annex 62 - Ventilative Cooling



**Paul D O'Sullivan**

Cork Institute of Technology

Brunel University London

- **Climate Cooling Potential**
- Annex 62 background, objectives, organisation
- CIT planned contribution to Annex 62
- CIT Zero2020 – A low energy retrofit Annex 62 case study
- Current work supporting Annex 62 objectives
- Planned work supporting Annex 62 objectives

# Climate Cooling Potential




- Nearly-zero energy buildings have led to an increased need for cooling – not only in summer but all year.
- Elevated temperature levels are the most reported problem in post occupancy studies - even in the “heating season”
- Cooling requirements in low energy buildings designed around heating energy reduction principles in cold climates are being underestimated with simplified tools
- Utilization of the **cooling potential** of outdoor air can be an attractive and energy efficient solution
- Cooling is correlated with solar and internal heat load and not outdoor temperature

- Annex 27 – domestic ventilation systems (air quality)
- Annex 28 – low energy cooling system
- Annex 35 – hybvent
- Annex 44 – building construction elements



# Climate Cooling Potential


## AAU work on Climatic potential of untreated outdoor air




### Climatic potential for night-time cooling

- Degree hours method to quantify the climatic cooling potential (CCP)
- Harmonically oscillating building temperature within a range of thermal comfort:  
 $T_b = 24.5^{\circ}\text{C} \pm 2.5^{\circ}\text{C}$
- Ventilation period:  
 7 pm – 7 am
- Minimum temperature difference:  
 $\Delta T_{crit} = 3\text{K}$

→ CCP (K h)

$$CCP_d = \sum_{t=t_1}^{t_2} m_{d,t} (T_{b(d,t)} - T_{e(d,t)}) \begin{cases} m = 1\text{h} & \text{if } T_b - T_e \geq \Delta T_{crit} \\ m = 0 & \text{if } T_b - T_e < \Delta T_{crit} \end{cases}$$


Shaded areas show the climatic cooling potential during one exceptionally hot week in summer 2003 for Zurich SMA (ANETZ data)



### Cumulative distribution

Percentage of summer nights when CCP exceeds e.g. 80 Kh

- Current climate: 90 %
- Future climate: 45-55 %

Significant increase in risk of overheating

Seasonal cumulative distribution functions of CCP in Madrid for current climate (ECA data) and selected simulation runs with mean values for forcing scenarios A2 and B2

*“Ventilative cooling potential of the outdoor air – now and in the future”. Per Heiselberg Annex 62 Workshop Brussels March 2013*

# Long/Short term Climate - Cork



Month	Cork Airport TMY3 95 <sup>th</sup> Percentile			CIT Stn. Summer 2013 95 <sup>th</sup> Percentile**		
	G <sub>h</sub> (Wh/m <sup>2</sup> )	T <sub>a</sub> (°C)	WS (m/s)	G <sub>h</sub> (Wh/m <sup>2</sup> )	T <sub>a</sub> (°C)	WS (m/s)
May	742	17.2	10.0	730	16.0	6.3
June	815	19.5	9.3	826	20.6	5.0
July	707	20.7	9.0	795	25.0	4.3
August†	662	20.0	9.3	567	19.1	4.7
September*	574	19.4	9.0	-	-	-

† Data up to 15<sup>th</sup> August only for short term; \*Data not yet available for short term; \*\*Data taken from zero2020 weather station

# Agenda



- Climate Cooling Potential
- Annex 62 background, objectives, organisation
- CIT planned contribution to Annex 62
- CIT Zero2020 – A low energy retrofit Annex 62 case study
- Current work supporting Annex 62 objectives
- Planned work supporting Annex 62 objectives

# Annex Leadership & Participants



- **Annex Work Phase Jan 2014 – Dec 2016**
- **Annex write up phase Jan – Dec 2017**
- **Operating Agent:** Denmark, AAU, (Prof. Per Heiselberg)
- **Subtask A:**
  - Leader: Switzerland, ESTIA
  - Co-leader: Italy, EURAC
- **Subtask B:**
  - Leader: Austria, IBRI
  - Co-leader: Germany, RWTH Aachen
- **Subtask C:**
  - Leader: Greece, NKUA
  - Co-leader: China, Hunan University




# Annex 62 Participants

Country	Institution	Subtask A	Subtask B	Subtask C	Probability
Austria	IBRI		X	X	Certain
Belgium	BBRI	X			Certain
	Loeven			X	Low
China	Hunan	X	X	X	Certain
Denmark	AAU	X	X		Certain
	DTU	X	X		Certain
	VELUX	X	X	X	Certain
	WindowMaster		X		Certain
Finland	FIOH		X		Certain
	SAMK	X			High
Germany	RWTH Aachen	X	X		High
Greece	NKUA	X	X	X	Certain
Ireland	CIT		X	X	Certain
Italy	EURAC	X			Certain
	POLIMI			X	Certain
Japan	OSAKA	X	X	X	Certain
	Ritsumeikan	X	X	X	Certain
Netherlands	Tu/e	X	X		Certain
	BBA Binnenm.	X			Certain
	TU Delft	X			High
Norway	NTNU		X	X	Certain
Sweden	LTH		X	X	Low
Switzerland	ESTIA	X			High
UK	Brunel		X	X	Certain
USA	MIT	X		X	High



Athens Workshop – Sept 23/24<sup>th</sup> 2013  
(Coincided with 34<sup>th</sup> AIVC Conference & 1<sup>st</sup> Venticool Conference)



# Definition of Ventilative Cooling



*“Ventilative Cooling is the application (distribution in time and space) of ventilation air flow to reduce cooling loads in buildings. Ventilative Cooling utilizes the cooling and thermal perception potential (higher air velocities) of outdoor air. In Ventilative Cooling the air driving force can be natural, mechanical or a combination”*

IEA-EBC Annex 62 text.

# Annex 62 Objectives

- To **analyse, develop and evaluate suitable methods and tools** for prediction of cooling need, ventilative cooling performance and risk of overheating in buildings that are suitable for design purposes. (Subtask A).
- To give **guidelines for integration of ventilative cooling in energy performance calculation methods** and regulations including specification and verification of key performance indicators (Subtask A). .....




# Annex 62 Objectives cont'd




- To extend the boundaries of existing ventilation solutions and their control strategies and **to develop recommendations for flexible and reliable ventilative cooling solutions** that can create comfortable conditions under a wide range of climatic conditions (Subtask B).
- To **demonstrate the performance of ventilative cooling solutions through analysis and evaluation** of well-documented case studies. (Subtask C).

The Annex will focus on (non exhaustive list):

- cooling and thermal perception potential of outdoor air.
- technical conditions needed to make ventilative cooling possible
- “large flow rate/high temp” and “small flow rate/low temp”
- impact of elevated air velocities & increased ventilation flow rates



- The Annex research focus will not be on solutions to increase the cooling potential of outdoor air by lowering its temperature through exploitation of heat exchange in earth ducts, ground water heat exchangers and similar technologies.
- The research focus will be on the exploitation of the cooling potential of untreated outdoor air.



# Agenda



- Climate Cooling Potential
- Annex 62 background, objectives, organisation
- **Outline of CIT planned contribution to Annex 62**
- CIT Zero2020 – A low energy retrofit Annex 62 case study
- Current work supporting Annex 62 objectives
- Planned work supporting Annex 62 objectives

- Subtask A: Methods and Tools
- Subtask B: Solutions (CIT will Contribute)
- Subtask C: Case Studies (CIT will Contribute)



# Subtask B & C

## Subtask B (Solutions):

- Will investigate the cooling performance of existing mechanical, natural and hybrid ventilation systems and typical comfort control solutions as a starting point for extending the boundaries for their use.
- Will develop recommendations for flexible and reliable ventilative cooling solutions that can create comfort under a wide range of climatic conditions.

**CIT will contribute to 6 of the 11 Activities in subtask B**

## Subtask C (Case Studies):

- The subtask will demonstrate the performance of ventilative cooling through analysis and evaluation of well-documented case studies.



**CIT will contribute to 3 of the 9 Activities in subtask C**

# Agenda

- Annex 62 background, objectives & overview
- Annex 62 Organisation
- CIT planned contribution to Annex 62
- **CIT Zero2020 – low energy retrofit**
- Current work supporting Annex 62 objectives
- Planned work supporting Annex 62 objectives

# ZERo2020 overview

The **'Zero2020' Project** is a project involving extensive refurbishment and upgrade of 3% of an existing 1974 office and teaching space on the Bishopstown Campus of Cork Institute of Technology as a pilot project.



*Its **mission** is to provide a live, monitored testbed environment to explore energy and resource performance through the use of low energy solutions with emphasis on demonstrating nearly zero energy in use operation.*

# ZERo2020 overview




# Opaque wall retrofit solution

Location	$\omega/\varphi$ (W/mK) / h	$f$ (W/mK)	$U_{wall}$ (W/m <sup>2</sup> K)	$U_{fenestr.}$ (W/m <sup>2</sup> K)
Control Space	<b>5.49 / 1.017</b>	<b>0.608</b>	3.633	6.0
Retrofit Space	<b>5.92 / 0.963</b>	<b>0.004</b>	0.090	0.84

## Opaque external wall retrofit details

Component 1-4 existing structure boundary

Component 5-8 new external envelope boundary



# Agenda



- Annex 62 background, objectives & overview
- Annex 62 Organisation
- CIT planned contribution to Annex 62
- CIT Zero2020 – low energy retrofit
- **Current work supporting Annex 62 objectives**
- Planned work supporting Annex 62 objectives

# Control & Retrofit Spaces





west facing retrofit test space



West facing control space




CIT Campus



29,000m<sup>2</sup> existing 1974 building wings A - D

# Fenestration Module



**Limiting dimension for  
ventilation opening  
heights**

**Modes of Operation**

**RE / 2 / M**

**RE / 3 / A**


**RE / 4 / M / A**




# Config & Tracer Conc Decay




Tests	<b>13</b>
Max ACH	<b>5.8</b>
Min ACH	<b>2.0</b>
$\sigma$	<b>1.2</b>
Mean	<b>3.7</b>




Tests	<b>13</b>
Max ACH	<b>5.8</b>
Min ACH	<b>2.1</b>
$\sigma$	<b>1.0</b>
Mean	<b>3.1</b>



Tests	<b>6</b>
Max ACH	<b>3.4</b>
Min ACH	<b>1.5</b>
$\sigma$	<b>1.0</b>
Mean	<b>2.2</b>



Tests	<b>6</b>
Max ACH	<b>4.4</b>
Min ACH	<b>1.2</b>
$\sigma$	<b>1.2</b>
Mean	<b>2.7</b>



# Analysis of Dominant Forces

Inertia & Buoyancy forces were studied for each ventilation rate test with aim of establishing combined effect of wind and thermal conditions

Archimedes number,  $Ar = (Gr/Re^2)$  described as:


$$Ar^{0.5} = \frac{\Delta T g H}{T v_{wind}^2}$$

Dimensionless Flow number,  $F$ , described as:



$$F = \frac{q_{ACH}}{A_{eff} v_{wind}}$$

The use of a flow number due to thermal stack effect alone,  $F_{th}$ , is introduced to the plot.



$$F_{th} = K \cdot Ar^{0.5} \text{ (Stack Dominant)}$$



# Warren Plot for CSI & RE4



Control Space



RE/4/M/A

Archimedes Number  $Ar^{0.5}$

Test Wind Direction & Speed



# Warren Plot for RE2 & RE3




RE/3.0/A




RE/2.0/M



Test Wind Direction & Speed




Archimedes Number  $Ar^{0.5}$



# Analysis of Zonal Stratification


## Str.Fr - Annex 35 HybVent

$$\frac{\Delta T_s}{\Delta T_{ie}} = \frac{T_H - T_0}{T_{H/2} - T_E}$$



StrFr Results for Test conditions close or equal to  $F_{th}$

Config	Test	Str Fr	$ F - F_{th} $	$Km^{-1}$
CS/1.0	3	0.227	0.002	0.49
CS/1.0	4	0.551	0.002	0.94
CS/1.0	27	0.565	0.001	1.00
CS/1.0	2	0.621	0.003	1.81
RE/2.0	29	0.700	0.002	1.30
CS/1.0	14	1.051	0.003	3.20
RE/3.0	25	1.111	0.002	1.20
RE/3.0	16	1.125	0.004	0.60
RE/4.0	32	1.438	0.001	0.80
RE/4.0	24	1.809	0.000	1.20



RE vs. CS stratification

## Analysis of overheating criteria retrofit and control space

Space.	hrs>25°C (%Σhrs)*	hrs>28°C (%Σhrs)*
Control	34	17
Retrofit	33	3.5

*\*Based on 981 working hours May-September*

## 20th June – 19th July 2013 Values $Str.Fr (\Delta T_s / \Delta T_{ie})$ Data

Space.	Occupied hours (09:00-18:00)				Unoccupied Hours (18:00-09:00)			
	50 <sup>th</sup>	75 <sup>th</sup>	95 <sup>th</sup>	% occ hrs > 1	50 <sup>th</sup>	75 <sup>th</sup>	95 <sup>th</sup>	% occ hrs > 1
Control	0.411	0.691	1.19	9.0%	0.192	0.333	0.622	0.0%
Retrofit	0.202	0.609	2.59	14.5%	0.157	0.290	0.611	2.2%

# Agenda




- Annex 62 background, objectives & overview
- Annex 62 Organisation
- CIT planned contribution to Annex 62
- CIT Zero2020 – low energy retrofit
- Current work supporting Annex 62 objectives
- **Planned work supporting Annex 62 objectives**

- More detailed study of single side ventilation rates
  - using wind measurements in 3D at approx. 32hz frequency
  - Age of air tests in ventilated zone
  - Air speeds at the inlet (some tests done a 1 minute test interval)
- Develop TRNSYS/COMIS multi-zone model for testbed
- Develop zonal flow model single zone using TRNSYS environ
- Investigate climate cooling potential for Irish Climate (NZEB)
- Study thermal perception potential for single sided ventilation



- Cooling increasingly important due to low energy buildings
- VC utilises thermal perception potential of untreated outdoor air
- Annex 62 addresses a range of requirements regarding VC technology (methods, modelling, applications, regulations)
- CIT will contribute using zero2020 low energy retrofit testbed



# Thank You

