




Operation and performance


Paul D O'Sullivan / MeSSO //STL 2015 // Architecture Factory

nZero.2020 / features & performance

## Agenda

- 1.Features
- 2.Asset rating & PHPP
- 3.Energy end use performance 2013
- 4.PHPP vs. measured data
- 5.Ventilation strategy
- 6.Long term indoor air temperatures 2013 & 2015
- 7.Thermal comfort evaluation
- 8.What are we learning...







20kWp PV Installation with 1kW  
wind turbine and Micro Grid



20kW dimplex dual compressor  
air source heat pump



manual & automated purpose provided  
ventilation openings with insulated doors






wireless Hanwell radio frequency based data logging system

# Energy Performance


How does the zero2020 retrofit solution compare with the existing building on an equivalence basis?

Building	Heating (kWh/m <sup>2</sup> /yr)	Lighting (kWh/m <sup>2</sup> /yr)	Auxiliary (kWh/m <sup>2</sup> /yr)	Hot Water (kWh/m <sup>2</sup> /yr)	Total (kWh/m <sup>2</sup> /yr)
1974	386.83	46.43	3.24	16.4	452.57
Zero2020	14.25	45.47	1.91	2.51	64.14



A PHPP model has been developed to investigate how the various losses & gains contribute to the reduction in heating demand





PHPP model shows a high solar gain contribution throughout the extended cooling season



2013 Monthly Totalised Energy Consumption per end use



## 2013 Monthly Totalised Energy Consumption per end use



2013 z2020 Delivered Heating Energy = 13.3 kWh/m<sup>2</sup> annual

2013 PHPP Delivered Heating Energy = 14.7 kWh/m<sup>2</sup> annual

Specific building demands with reference to the treated floor area			use: Monthly method	
		222.5 m <sup>2</sup>	Requirements	Fulfilled?*
<b>Space heating</b>	Treated floor area	222.5 m <sup>2</sup>		
	Annual heating demand	14 kWh/(m <sup>2</sup> a)	25 kWh/(m <sup>2</sup> a)	yes
	Heating load	25 W/m <sup>2</sup>	-	-
<b>Space cooling</b>	Overall specific space cooling demand	kWh/(m <sup>2</sup> a)	-	-
	Cooling load	W/m <sup>2</sup>	-	-
	Frequency of overheating (> 25 °C)	0.0 %	-	-
<b>Primary Energy</b>	Space heating and cooling, dehumidification, household electricity.	kWh/(m <sup>2</sup> a)	120 kWh/(m <sup>2</sup> a)	-
	DHW, space heating and auxiliary electricity	kWh/(m <sup>2</sup> a)	-	-
	Specific primary energy reduction through solar electricity	0 kWh/(m <sup>2</sup> a)	-	-
<b>Airtightness</b>	Pressurization test result n <sub>50</sub>	1.6 1/h	1 1/h	no

\* empty field: data missing; '-': no requirement



# Single Sided Natural Ventilation Rates

Manual & Automated Ventilation Configurations

CS.01







RS.02



RS.03





RS.04






Tracer Gas Concentration Decay Tests investigating measured ventilation rates (pre and post retrofit)




Boxplot distributions of Single Sided ventilation ACH according to configurations




# Indoor Air Temperature & Overheating Risk

% of Total Monthly Hours for Indoor Air Temperature 2013




# Heat map Open Plan office 2013







## Heat map Open Plan office 2013




## Heat map > 25°C Open Plan office 2013




## Heat map > 28°C Open Plan office 2013




## Heat map Open Plan office 2015




## Heat map Open Plan office 2015



## Heat map > 25°C Open Plan office 2015



## Heat map > 28°C Open Plan office 2015







Summary Open Plan (All hours) office 2013 & 2015

**2015 Total Hours**


No. hrs > 25 = 0.15%

No. hrs > 28 = 0%


**2015 Occupied Hours**

No. hrs > 25 = 0.034%



No. hrs > 28 = 0%








## Thermal Comfort




Ventilative cooling performance in a simulated overheating scenario




	2 Bi-directional anemometers (on x and y axis)
	3 air temperature sensors (0.1m ; 0.6m ; 1.1m)
	Black globe thermometer
	Relative humidity sensor




Study set up / methodology



Measured indoor air temperature profiles during thermal comfort tests for each ventilation configuration



## Recorded PMV from subjective survey data along with a comparison to the Fanger PMV model



Manual & Automated Ventilation Configurations

CS.01







RS.02



RS.03



RS.04





What are we learning?

- More data showing people like natural ventilation & openable windows
- PHPP gives realistic predictions for heating energy consumption even within non residential environments
- Surprisingly, so did SBEM for annualised values
- Up to 4 ACH possible with NV SS slot louver systems
- Low energy can mean comfortable but adaptive approach important (free running buildings)
- Overheating still likely even with night cooling
- It is difficult to obtain consistent, accurate measurements over extended periods of time

IEA-EBC Annex 62 Ventilative Cooling

[www.venticool.eu](http://www.venticool.eu)



Thermal perception potential of untreated outdoor air for low energy, well insulated, airtight buildings

Improve modelling techniques, guidelines, standards to better account for the contribution to minimising cooling demand

nzero.2020 is a case study

We also are undertaking occupancy evaluation surveys in buildings that utilise ventilative cooling in Cork (and hopefully elsewhere)




Cork County Hall  
- approximately 500 occupants

UCC WGB  
- approximately 200 occupants

During the warmer months, how satisfied are you with the temperature in your workspace?

Cork County Hall




UCC western Gateway




When you are dissatisfied, how would you describe the temperature?

Cork County Hall




UCC western Gateway




Finally, if you could move to a workspace with air conditioning but no openable windows, would you?

Cork County Hall



UCC western Gateway





nZero.2020 / People

