

Overheating risk and ventilative cooling in low energy retrofits: a case study at zero2020

Paul D O'Sullivan

MeSSO Research (<http://messo.cit.ie>)

School of Mechanical, Electrical & Process Engineering
Cork Institute of Technology




Engineers Ireland Cork Annual Seminar - 21st March 2017


Agenda

1. zero.2020 energy performance
2. ventilative cooling
3. overheating Risk
4. climate cooling potential at zero2020
5. what are we learning...

What motivates an organisation to undergo a low energy retrofit?




(A) Motivating Factors




(B) Barriers

What defines the scope for a low energy retrofit?




Influencing Factors



Energy Hierarchy

nZero.2020 / features





December 2012




February 2012



May 2012



September 2012



No	Description	Dim (mm)
1	Existing Internal Block	100
2	BASF Wall-tite Spray Foam	86
3	Existing aggregate panel	125
4	Air gap	30
5	Kingspan benchmark ceramic granite panel	12
6	Kingspan support rail	37
7	Kingspan KS 1100 insulated panel	125
8	AMS support mullion	125

5

Air permeability of
 $1.76 \text{ (m}^3\text{/hr) / m}^2$ at 50Pa
 building pressure.

6


7

The existing structure
 was measured as 14.77
 $\text{(m}^3\text{/hr) / m}^2$

8

Opaque External Envelope Retrofit

95% reduction in thermal transmittance



External Roof Retrofit


91% reduction in thermal transmittance



20kWp PV Installation with 1kW
wind turbine and Micro Grid



20kW dimplex dual compressor
air source heat pump



manual & automated purpose provided ventilation openings with insulated doors



wireless Hanwell radio frequency based data logging system



zero2020 Energy
Performance

How does the zero2020 retrofit solution compare with the existing building on an equivalence basis?

Building	Heating (kWh/m²/yr)	Lighting (kWh/m²/yr)	Auxiliary (kWh/m²/yr)	Hot Water (kWh/m²/yr)	Total (kWh/m²/yr)
1974	386.83	46.43	3.24	16.4	452.57
Zero2020	14.25	45.47	1.91	2.51	64.14



96% reduction of heating energy consumption

PHPP model results



2013 PHPP Delivered Heating Energy = 14.7 kWh/m² annual

2013 Monthly Totalised Energy Consumption per end use



2013 z2020 Delivered Heating Energy = 13.3 kWh/m² annual



D2



A3


Component	CIT (1974)	TGDL (2008)	TGDL (2017)	Cost Optimal	Zero2020
Wall U-value (W/m ² K):	2	0.6	0.21	0.3	0.09
Roof U-value (W/m ² K):	1.1	0.35	0.20	0.15	0.09
Floor U-value (W/m ² K):	0.8	0.8	0.21	0.10	0.8
Window U-value (W/m ² K):	>5	2.2	1.8	1.8	1

Can ventilative cooling
provide a comfortable
environment?

Most modern office buildings use mechanical cooling in moments when an optimized natural ventilation (NV) system could work.

Lower energy consumption could be a driver for increased NV use...but **energy costs** are one to two **orders of magnitude less than rent costs.**


NV needs to impose itself by its capability to **improve the work environment and worker productivity** as well as its contribution to climate change mitigation.



***Ventilative Cooling** is the application (distribution in time and space) of ventilation air flow to reduce cooling loads in buildings.*

Nearly-zero energy buildings have lead to **an increased need for cooling** - not only in summer but all year.

Elevated temperature levels are the most reported problem in post occupancy studies - even in the "heating season"



Map of mean climatic cooling potential (Kh/night) in July based on Meteonorm data [13].

ventilative cooling

IEA-EBC Annex 62
 Ventilative Cooling

www.venticool.eu

Improve modelling techniques, guidelines, standards to better account for the contribution to minimising cooling demand

nzero.2020 is a case study

2 new European standards for ventilative cooling planned

Country	Institution
Austria	IBRI
Belgium	BBRI
	Loeven
	VELUX
China	Hunan
	WindowMaster
Denmark	AAU
	DTU
Finland	FIOH
	SAMK
Germany	RWTH Aachen
Greece	NKUA
Ireland	CIT
Italy	EURAC
	POLIMI
Japan	OSAKA
	Ritsumeikan
Netherlands	Tu/e
	BBA Binnenm.
	TU Delft
Norway	NTNU
Sweden	LTH
Switzerland	ESTIA
UK	Brunel
USA	MIT





Fully integrated factory assembled module

Quadruple glazed unit c/w sealed triple glazed Argon filled system/ manual interstitial blinds / inner clear float pane

Integrated insulated ventilation doors low level occupancy controlled & high level BMS automated

Free-running indoor temperature as no HVAC system is used

Manual & Automated Ventilation Configurations

1974







auto



manual



combined




Indoor Temperature & Overheating Risk

Traditionally the criteria to assess overheating risk was a static threshold:

% of occupied hours equal to or above a certain threshold value:

- CIBSE: 5% > 25°C
- BRE: 1% > 28°C







Adaptive approach to thermal comfort in free running buildings – moving target for comfort


Local air movement are major factor in extending the thermal comfort range

CIBSE Propose 3 new criterion. Not just static % hours exceedance

Criterion 1:

The Number of Hours that the operative temperature can exceed the threshold comfort temperature by 1K or more during occupied hours of a typical non heating season shall not be more than 3% of occupied hours.





Open Plan
Office 2013

(not fully
occupied!)



Room	Name	CR1	CR2	CR3	h^*
B287	CAMMS Seminar Room	0	0	0	0.0000
B289	Conference Room	0.6	0	0	0.0050
B290	CAMMS Secretary Office	0.2	1	2	0.0020
B291	CAMMS Managers Office	0	0	0	0.0006
B294	MeSSO Open Plan Office	1.05	0	0	0.9800

How do we quantify
climate cooling
potential?

Need to consider the relationship between:

- Free running building temperature
- Outdoor temperature
- Comfort limits

Free cooling available - especially in mild climates






- How often is this cooling potential available?
- When is Ventilative Cooling needed?
- What is the required flowrate?

Mode	Description	Vent Rate	Code
0	Outdoor temperature is below the balance point temperature - heating mode	Min IAQ	Red
1	When outdoor temperature exceeds balance point temperature - cooling mode; minimum required IAQ rate can provide cooling requirements	Min IAQ	Amber
2	Cooling mode; Enhanced ventilation is needed to satisfy the comfort temperature requirements	Enhanced VC	Blue

CCP - Part I 2008

Parameter	Value	Units
U - wall / U-roof	0.6 / 0.35	W/m ² K
U - glazing	2.2	W/m ² K
G - glazing	0.8	-
Shading control setpoint	50	W/m ²
Min vent rate	12	l/sp
Lighting power	11	W/m ²
Equip power	10.2	W/m ²
Occupancy	10	m ² p






Cooling hrs - 51%

Mean Vent Rate - 2.2 ACH

SD Vent Rate - 1.8 ACH

CCP - Part I 2017




Parameter	Value	Units
U - wall / U - roof	0.21 / 0.20	W/m ² K
U - glazing	1.8	W/m ² K
G - glazing	0.65	-
Shading control setpoint	50	W/m ²
Min vent rate	12	l/sp
Lighting power	11	W/m ²
Equip power	10.2	W/m ²
Occupancy	10	m ² p



Cooling hrs - 69%
 Mean Vent Rate - 2.5 ACH
 SD Vent Rate - 1.6 ACH

CCP - Proposed Cost Optimal

Parameter	Value	Units
U - wall / U - roof	0.3 / 0.15	W/m ² K
U - glazing	1.8	W/m ² K
G - glazing	0.65	-
Shading control setpoint	50	W/m ²
Min vent rate	12	l/sp
Lighting power	11	W/m ²
Equip power	10.2	W/m ²
Occupancy	10	m ² p



VC Mode ■ No VC ■ Min ACR ■ Enhanced ACR




Cooling hrs - 68%

Mean Vent Rate - 2.5 ACH

SD Vent Rate - 1.6 ACH

CCP - zero2020

Parameter	Value	Units
U - opaque	0.10	W/m ² K
U - glazing	1.09	W/m ² K
G - glazing	0.517	-
Shading control setpoint	50	W/m ²
Min vent rate	12	l/sp
Lighting power	11	W/m ²
Equip power	10.2	W/m ²
Occupancy	10	m ² p




Cooling hrs - 82%

Mean Vent Rate - 2.7 ACH


SD Vent Rate - 1.5 ACH

If you could move to a workspace with air conditioning but no openable windows, would you?

Cork County Hall thermal comfort occupant survey 2014 - 110 respondents




UCC WGB thermal comfort occupant survey 2014 - 40 respondents



What are we learning?

- More data showing people like natural ventilation & openable windows
- Low-energy can mean comfortable but adaptive approach important (free running buildings)
- Overheating will be an issue in low energy retrofits depending on level of upgrade even with night cooling
- Cooling needs are increasing with new and refurbished buildings and cooling season is extending
- Good climate cooling potential exists in Ireland and can offset cooling energy loads (100% in some cases)
- Good component design needed to ensure required ventilation rates are achieved

A thermal image of a building at night. The building's facade is covered in a color gradient representing heat, with red and yellow indicating warmer areas, particularly around the windows. A person is walking in the foreground on the right side, also appearing as a bright yellow and red shape. The background is dark blue, indicating a cool environment.



Thank you for listening.

<http://messo.cit.ie/nbert>

www.zero2020energy.com

Availability of energy for cooling from untreated outdoor air is dependant on:

- the threshold comfort temperature (standards)
- the outdoor temperature (climate)
- Solar irradiation (climate)
- Ventilation rate (openings)
- Building thermophysical properties (u-values etc)
- Building usage patterns (people, pc's, etc)



Thermal Comfort Study 05.2015 / 35 participants / 4 configurations



Config.	MTSV	PD _{per}	PD _{pref}	PD _f	ISO 7730	EN 15251	ASHRAE 55
RS-01	1.3	46%	46%	40%	-	IV	Unacceptable
RS-02	-0.5	20%	6%	10%	C	III	Acceptable
RS-03	-0.4	14%	3%	8%	B	II	Acceptable
RS-04	-1.1	34%	17%	29%	-	IV	Unacceptable